



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 46.9-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY -- Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R322 Flood-resistant construction		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change section R322 as follows:</p> <ol style="list-style-type: none">(1) Change R322.1 as follows: ... flood hazard areas (including A or V Zones) as established in Table R301.2(1) shall be designed...(2) Delete the text of R322.1.4 and substitute as follows: <u>Flood design elevations shall be determined by local flood control ordinance.</u>(3) Change R322.1.7 as follows; ... in accordance with the plumbing provisions of this code and Chapter 3 of the International Private Sewage Disposal Code.(4) Change R322.1.10 as follows: <u>When required by local ordinance a A registered design professional...</u>(5) Change R322.2.1, item #1, as follows: ...the lowest floors elevated to or above the design flood 2 feet (610 mm) above the 100 year flood elevation.		
REASON AND FISCAL IMPACT		
<p>While the zoning people determine flood areas the residential code needs to address the construction in theses areas. This proposal attempts to address FEMA rules and Indiana's rules in regard to construction in flood areas; to that end few changes are actually proposed to this section since during research on this issue few discrepancies with what is required by the state and federal programs were found.</p> <p>Fiscal impact: none since these rules are currently required.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		